

REHAB CONSULTANTS PVT. LTD.INVESTIGATION EVALUATION PLANNING DESIGN REHABILITATION
OF
CIVIL ENGINEERING STRUCTURES27, 6th Floor, Neelam Gulzar, Plot No. 24, Highway Service Road, Opp. Andheri Flyover, Near Garware Signal,
Off. Andheri Sahar Road, Andheri (E), Mumbai - 400 099. Tel.: 2839 3037

MVC/2018/679/047

Jan.19, 2018

STRUCTURAL STABILITY CERTIFICATE**FOR****ST. JOHN UNIVERSAL SCHOOL****AT****GOREGAON WEST, MUMBAI 400 104.**

JOB : Structural Audit of Stilt + 7 Storied School building, at
Goregaon West, Mumbai 400 104.

PRELUDE : Structural Audit is carried out as per instructions of
Management of St. John Universal School at Goregaon (W).

After considering our own assessment based on our experience of last 29 Years and results of NDT submitted by 3 agencies and the Geotechnical report submitted by M/s GEOCON Consultants, we feel that the building falls in grade C2-B. **The building is safe and stable & fit for human habitation.** It needs to be repaired in near future. Being school building it is advisable to carry out necessary repairs in summer vacation i.e. in April & May 2018.

For **REHAB CONSULTANTS PVT. LTD.**

Milind V. Chindarkar
Director (Consulting Structural Engineer)
MCGM/STR/C-37



(Grade C2-B - Minor to major repairs but building need not to be vacated during repairs)